

HPD UNIQUE IDENTIFIER: 25259
CLASSIFICATION: 09 69 00 Access Flooring
PRODUCT DESCRIPTION: TL5 is a 25mm high-density particle board screw-down raised access floor panel, capable of handling an ultimate load of more than 10kN. Its slim design of just 26mm total height means it's perfect for confined floor heights and refurbishment projects.

Section 1: Summary

Nested Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format	Threshold level	Residuals/Impurities	<i>All Substances Above the Threshold Indicated Are:</i> Characterized ☐ Yes Ex/SC ☒ Yes ☐ No <i>% weight and role provided for all substances.</i> Screened ☐ Yes Ex/SC ☒ Yes ☐ No <i>All substances screened using Priority Hazard Lists with results disclosed.</i> Identified ☐ Yes Ex/SC ☐ Yes ☒ No <i>One or more substances not disclosed by Name (Specific or Generic) and Identifier and/ or one or more Special Condition did not follow guidance.</i>
☒ Nested Materials Method	☒ 100 ppm	Residuals/Impurities	
☐ Basic Method	☐ 1,000 ppm	Considered in 3 of 3 Materials	
Threshold Disclosed Per	☐ Per GHS SDS	Explanation(s) provided for Residuals/Impurities?	
☐ Material	☐ Other	☒ Yes ☐ No	
☒ Product			

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

MATERIAL | SUBSTANCE | RESIDUAL OR IMPURITY
GREENSCREEN SCORE | HAZARD TYPE
PARTICLE BOARD [WOOD FIBER - UNSPECIFIED NoGS UREA, POLYMER WITH AMMONIA AND FORMALDEHYDE LT-UNK WATER BM-4 UNDISCLOSED LT-UNK UNDISCLOSED LT-UNK] STEEL, GALVANISED [IRON, ELEMENTAL LT-P1 | END ZINC, ELEMENTAL LT-P1 | AQU | END | MUL | PHY PHOSPHORUS BM-2 | MAM | PHY TITANIUM LT-UNK SILICON, ELEMENTAL LT-UNK MANGANESE LT-P1 | END | MUL | REP CARBON LT-UNK] POLYURETHANE ADHESIVE [UNDISCLOSED LT-UNK UNDISCLOSED NoGS UNDISCLOSED LT-UNK | CAN | MUL | RES | SKI | EYE UNDISCLOSED LT-P1 | MUL | RES UNDISCLOSED LT-UNK UNDISCLOSED BM-1 | CAN]

Number of Greenscreen BM-4/BM3 contents ... 1
Contents highest concern GreenScreen Benchmark or List translator Score ... BM-1
Nanomaterial ... No
INVENTORY AND SCREENING NOTES:
The Quartz database for common building materials was used when the manufacturer's information was lacking CAS identifiers or in cases where the material is not manufactured by Kingspan and secondary material information has been relied on. Comparing and contrasting Kingspan's own documentation against the generic product database allowed for a more robust screening than using the documentation alone.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

CERTIFICATIONS AND COMPLIANCE See Section 3 for additional listings.
VOC emissions: CDPH Standard Method V1.1 (Section 01350/CHPS) - Classroom & Office scenario
LCA: Environmental Product Declaration by EuGeos
Sustainable forestry: FSC Certification - Chain of Custody (COC)

CONSISTENCY WITH OTHER PROGRAMS

No pre-checks completed or disclosed.

Third Party Verified? ☐ Yes ☒ No	PREPARER: Self-Prepared VERIFIER: VERIFICATION #:	SCREENING DATE: 2021-07-01 PUBLISHED DATE: 2021-07-06 EXPIRY DATE: 2024-07-01
---	---	---

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- *Basic Inventory method with Product-level threshold.*
- *Nested Material Inventory method with Product-level threshold*
- *Nested Material Inventory method with individual Material-level thresholds*

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.2, available on the HPDC website at: www.hpd-collaborative.org/hpd-2-2-standard

PARTICLE BOARD

%: 66.7000 - 67.2000

PRODUCT THRESHOLD: 100 ppm RESIDUALS AND IMPURITIES CONSIDERED: Yes MATERIAL TYPE: Wood Dust, Fiber or Chips

RESIDUALS AND IMPURITIES NOTES: The product contains wood from various sources with uncharacterised residuals

OTHER MATERIAL NOTES:

WOOD FIBER - UNSPECIFIED

ID: Not registered

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library HAZARD SCREENING DATE: 2021-07-01 1:28:24

%: 76.0000 - 84.0000 GS: NoGS RC: Both NANO: No SUBSTANCE ROLE: Biological material

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

None found

No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES: wood chip of mixed origin

UREA, POLYMER WITH AMMONIA AND FORMALDEHYDE

ID: 27967-29-9

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library HAZARD SCREENING DATE: 2021-07-01 1:28:25

%: 9.0000 - 10.0000 GS: LT-UNK RC: None NANO: No SUBSTANCE ROLE: Binder

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

None found

No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES:

WATER

ID: 7732-18-5

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library HAZARD SCREENING DATE: 2021-07-01 1:28:25

%: 7.0000 - 10.0000 GS: BM-4 RC: UNK NANO: No SUBSTANCE ROLE: Biological material

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

None found

No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES:

UNDISCLOSED

ID: Undisclosed

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library HAZARD SCREENING DATE: 2021-07-01 1:28:31

%: 0.0000 - 1.0000		GS: LT-UNK	RC: UNK	NANO: No	SUBSTANCE ROLE: Viscosity modifier
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
None found			No warnings found on HPD Priority Hazard Lists		
SUBSTANCE NOTES: actual role of substance in resin formulation is uncertain					

UNDISCLOSED

ID: Undisclosed

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:31			
%: 0.0000 - 1.0000		GS: LT-UNK	RC: UNK	NANO: No	SUBSTANCE ROLE: Viscosity modifier
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
None found			No warnings found on HPD Priority Hazard Lists		
SUBSTANCE NOTES: actual role in resin formualtion is uncertain					

STEEL, GALVANISED		%: 31.7000 - 32.3000			
PRODUCT THRESHOLD: 100 ppm		RESIDUALS AND IMPURITIES CONSIDERED: Yes		MATERIAL TYPE: Metal	
RESIDUALS AND IMPURITIES NOTES: Any residuals and impurities are those common in galvanised steels					
OTHER MATERIAL NOTES:					

IRON, ELEMENTAL

ID: 7439-89-6

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:24		
%: 94.5000 - 98.2000		GS: LT-P1		RC: Both NANO: No SUBSTANCE ROLE: Alloy element
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS	
END	TEDX - Potential Endocrine Disruptors		Potential Endocrine Disruptor	
SUBSTANCE NOTES:				

ZINC, ELEMENTAL

ID: 7440-66-6

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:26			
%: 1.2500 - 3.2500		GS: LT-P1	RC: UNK	NANO: No	SUBSTANCE ROLE: Coating

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
AQU	EU - GHS (H-Statements)	H400 - Very toxic to aquatic life
AQU	EU - GHS (H-Statements)	H410 - Very toxic to aquatic life with long lasting effects
END	TEDX - Potential Endocrine Disruptors	Potential Endocrine Disruptor
MUL	German FEA - Substances Hazardous to Waters	Class 2 - Hazard to Waters
PHY	EU - GHS (H-Statements)	H250 - Catches fire spontaneously if exposed to air
PHY	EU - GHS (H-Statements)	H260 - In contact with water releases flammable gases which may ignite spontaneously
SUBSTANCE NOTES: Corrosion protective coating		

PHOSPHORUS

ID: 7723-14-0

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:29				
%: 0.0000 - 0.1100		GS: BM-2		RC: UNK	NANO: No	SUBSTANCE ROLE: Alloy element
HAZARD TYPE		AGENCY AND LIST TITLES		WARNINGS		
MAM		US EPA - EPCRA Extremely Hazardous Substances		Extremely Hazardous Substances		
PHY		EU - GHS (H-Statements)		H228 - Flammable solid		
SUBSTANCE NOTES:						

TITANIUM

ID: 7440-32-6

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:29		
%: 0.0000 - 0.3000	GS: LT-UNK	RC: Both	NANO: No	SUBSTANCE ROLE: Alloy element
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS	
None found	No warnings found on HPD Priority Hazard Lists			
SUBSTANCE NOTES: Present in base steel				

SILICON, ELEMENTAL

ID: 7440-21-3

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:29		
%: 0.0000 - 0.0040	GS: LT-UNK	RC: Both	NANO: No	SUBSTANCE ROLE: Alloy element
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS	
None found	No warnings found on HPD Priority Hazard Lists			
SUBSTANCE NOTES: Present in base steel				

MANGANESE			ID: 7439-96-5		
HAZARD SCREENING METHOD: Pharos Chemical and Materials Library			HAZARD SCREENING DATE: 2021-07-01 1:28:30		
%: 0.0000 - 1.1000		GS: LT-P1	RC: Both	NANO: No	SUBSTANCE ROLE: Alloy element
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
END	TEDX - Potential Endocrine Disruptors		Potential Endocrine Disruptor		
MUL	German FEA - Substances Hazardous to Waters		Class 2 - Hazard to Waters		
REP	GHS - Japan		Toxic to reproduction - Category 1B [H360]		
SUBSTANCE NOTES: Present in base steel					

CARBON			ID: 7440-44-0		
HAZARD SCREENING METHOD: Pharos Chemical and Materials Library			HAZARD SCREENING DATE: 2021-07-01 1:28:30		
%: 0.0000 - 0.1700		GS: LT-UNK	RC: Both	NANO: No	SUBSTANCE ROLE: Alloy element
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
None found			No warnings found on HPD Priority Hazard Lists		
SUBSTANCE NOTES:					

POLYURETHANE ADHESIVE		%: 0.5000 - 0.7000	
PRODUCT THRESHOLD: 100 ppm	RESIDUALS AND IMPURITIES CONSIDERED: Yes		MATERIAL TYPE: Polymeric Material
RESIDUALS AND IMPURITIES NOTES: Residuals and impurities likely to be present in generic materials of this type have been considered			
OTHER MATERIAL NOTES:			

UNDISCLOSED			ID: Undisclosed		
HAZARD SCREENING METHOD: Pharos Chemical and Materials Library			HAZARD SCREENING DATE: 2021-07-01 1:28:25		
%: 69.0000 - 75.0000		GS: LT-UNK	RC: UNK	NANO: No	SUBSTANCE ROLE: Polymer species
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
None found			No warnings found on HPD Priority Hazard Lists		
SUBSTANCE NOTES: Typical polyurethane formed by reaction of di-isocyanates and polyols: exact PU present in this adhesive is not known					

UNDISCLOSED			ID: Undisclosed		
HAZARD SCREENING METHOD: Pharos Chemical and Materials Library			HAZARD SCREENING DATE: 2021-07-01 1:28:26		
%: Impurity/Residual		GS: NoGS	RC: None	NANO: No	SUBSTANCE ROLE: Impurity/Residual
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS		
None found			No warnings found on HPD Priority Hazard Lists		

SUBSTANCE NOTES: Possible residual of generic pre-polymer material

UNDISCLOSED

ID: **Undisclosed**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2021-07-01 1:28:27**

?: **Impurity/Residual**

GS: **LT-UNK**

RC: **UNK**

NANO: **No**

SUBSTANCE ROLE: **Impurity/Residual**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
CAN	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
MUL	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
RES	AOEC - Asthmagens	Asthmagen (G) - generally accepted
CAN	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
SKI	EU - GHS (H-Statements)	H315 - Causes skin irritation
EYE	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RES	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization
RES	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
SKI	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
RES	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage

SUBSTANCE NOTES: Possible residual monomer from PU formation

UNDISCLOSED

ID: **Undisclosed**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2021-07-01 1:28:27**

?: **Impurity/Residual**

GS: **LT-P1**

RC: **None**

NANO: **No**

SUBSTANCE ROLE: **Impurity/Residual**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
MUL	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
RES	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage

SUBSTANCE NOTES: Possible residual from polyurethane formation

UNDISCLOSED

ID: **Undisclosed**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2021-07-01 1:28:28**

?: **0.0000 - 22.5000**

GS: **LT-UNK**

RC: **UNK**

NANO: **No**

SUBSTANCE ROLE: **Viscosity modifier**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES: Limestone, in powder form, may also serve as a filler

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library		HAZARD SCREENING DATE: 2021-07-01 1:28:28	
%: 0.0000 - 22.5000		GS: BM-1	RC: UNK NANO: No SUBSTANCE ROLE: Viscosity modifier
HAZARD TYPE	AGENCY AND LIST TITLES		WARNINGS
CAN	GHS - Australia		H350i - May cause cancer by inhalation
CAN	GHS - Japan		Carcinogenicity - Category 1A [H350]
SUBSTANCE NOTES: Silica may also serve as a filler			

Section 3: Certifications and Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS		CDPH Standard Method V1.1 (Section 01350/CHPS) - Classroom & Office scenario	
CERTIFYING PARTY: Third Party	ISSUE DATE: 2015-01-	EXPIRY DATE:	CERTIFIER OR LAB: Eurofins
APPLICABLE FACILITIES: Kingspan Access Floors, Marfleet, Hull, UK	27		Product Testing A/S
CERTIFICATE URL:			
CERTIFICATION AND COMPLIANCE NOTES: Meets VOC emissions specifications in LEED EQ credit "Low-emitting products"; the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m ³ in both office and classroom			
LCA		Environmental Product Declaration by EuGeos	
CERTIFYING PARTY: Third Party	ISSUE DATE: 2021-03-	EXPIRY DATE: 2026-	CERTIFIER OR LAB: Ugo Pretato,
APPLICABLE FACILITIES: Kingspan Access Floors, Marfleet, Hull, UK	29	03-28	Studie Fieschi
CERTIFICATE URL:			
CERTIFICATION AND COMPLIANCE NOTES:			
SUSTAINABLE FORESTRY		FSC Certification - Chain of Custody (COC)	
CERTIFYING PARTY: Third Party	ISSUE DATE: 2017-09-	EXPIRY DATE: 2022-	CERTIFIER OR LAB: SGS
APPLICABLE FACILITIES: Kingspan Access Floors, Marfleet, Hull, UK	27	09-26	
CERTIFICATE URL:			
CERTIFICATION AND COMPLIANCE NOTES:			

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

Kingspan Access Flooring Limited manufacturers raised flooring systems. When screening Kingspan's products consider the following options: 1. flooring panel 2. pedestal 3. stringer, if used.

MANUFACTURER INFORMATION

MANUFACTURER: Kingspan Access Floors Ltd
ADDRESS: Burma Drive
Marfleet Hull HU9 5SG, UK
WEBSITE: <http://www.kingspanaccessfloors.co.uk>

CONTACT NAME: Technical Sales
TITLE: Technical Sales
PHONE: +44 (0) 1482 781701
EMAIL: info@kingspanaccessfloors.co.uk

The listed contact is responsible for the validity of this HPD and attests that it is accurate and complete to the best of his or her knowledge.

KEY

Hazard Types

AQU Aquatic toxicity	LAN Land toxicity	PHY Physical hazard (flammable or reactive)
CAN Cancer	MAM Mammalian/systemic/organ toxicity	REP Reproductive
DEV Developmental toxicity	MUL Multiple	RES Respiratory sensitization
END Endocrine activity	NEU Neurotoxicity	SKI Skin sensitization/irritation/corrosivity
EYE Eye irritation/corrosivity	NF Not found on Priority Hazard Lists	UNK Unknown
GEN Gene mutation	OZO Ozone depletion	
GLO Global warming	PBT Persistent, bioaccumulative, and toxic	

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)	LT-1 List Translator 1 (Likely Benchmark-1)
BM-3 Benchmark 3 (use but still opportunity for improvement)	LT-UNK List Translator Benchmark Unknown (the chemical is present on at least one GreenScreen Specified List, but the information contained within the list did not result in a clear mapping to a LT-1 or LTP1 score.)
BM-2 Benchmark 2 (use but search for safer substitutes)	
BM-1 Benchmark 1 (avoid - chemical of high concern)	
BM-U Benchmark Unspecified (due to insufficient data)	
LT-P1 List Translator Possible 1 (Possible Benchmark-1)	NoGS No GreenScreen.

Recycled Types

PreC Pre-consumer recycled content
PostC Post-consumer recycled content
UNK Inclusion of recycled content is unknown
None Does not include recycled content

Other Terms:

GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Inventory Methods:

Nested Method / Material Threshold Substances listed within each material per threshold indicated per material
Nested Method / Product Threshold Substances listed within each material per threshold indicated per product
Basic Method / Product Threshold Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology

Third Party Verified Verification by independent certifier approved by HPDC

Preparer Third party preparer, if not self-prepared by manufacturer

Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- *a method for the assessment of exposure or risk associated with product handling or use,*
- *a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.*

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.